
60E10



UNDERPASS LIGHTING SCHEMATIC DIAGRAM

TRIMMED CABLES -- COMPRESSION TYPE COPPER SLEEVE (SIZED FOR ACTUAL NUMBER OF CABLES HEAT-SHRINKABLE CAP WITH FACTORY APPLIED WATERPROOF SEALANT (SIZED TO ACCOMMODATE AND MFR. SUGGESTED CRIMP TOOL USED) - SEALANT TAPE OR INSERT (AROUND THE REQUIRED NUMBER OF CABLES) AND THROUGH CROTCH OF SPLICE) ELECTRIC FEEDER CABLES SUCH AS CABLE IN UNIT DUCT OR IN CONDUIT (SIZE AS NOTED -EXPOSED SEALANT ON CONTRACT DRAWINGS) NOTE THAT NUMBER OF ELECTRIC CABLE TO LUMINAIRE (SIZE CABLES IN SPLICE MAY VARY. AS NOTED ELSEWHERE IN THESE CONTRACT DOCUMENTS) ___

CABLE SPLICING DETAIL

SCALE: N.T.S.

DRAWING No. E-29

	REVISIONS		ILLINOIS DEPARTMENT OF TRANSPORTATION		
	NAME	DATE	TELLINOIS DEL PARTIMENT SI	A11011	
			US RTE 6 FROM I-294 TO IL RTE 1 UNDERPASS LIGHTING SCHEMATIC & CABLE SPLICING DETAIL		
•					
Delta Engineering, Inc.			SCALE AS NOTED	DRAWN BY S.S./W.S.	S.S./W.S.
			DATE 12/12/07	CHECKED BY	C.K/H.S.